



1500 Brigantine Drive  
Coquitlam, BC, V3K 7C1

Telephone: 604-520-3321  
Facsimile: 604-524-9186  
www.intertek.com

July 15, 2016

Project No. G102570996

Carmen Bellavia  
EternaTile Inc.  
111 Briny Ave.  
Pompano Beach, FL 33062  
USA

Ph: 561-165-5103  
Email: Carmen.pres@eternatile.com

**Subject: Findings Letter 102570996COQ-001A**

Dear Carmen Bellavia,



Intertek has conducted physical testing on your coated foam product in accordance with the following:

- ASTM D1623-09, *Standard Test Method for Tensile and Tensile Adhesion Properties of Rigid Cellular Plastics*
- ASTM D1621-16, *Standard Test Method for Compressive Properties of Rigid Cellular Plastics*

Samples were received at the Evaluation Center on May 12, 2016 (Coquitlam ID# VAN1605170818-001). Test results can be found in Table 1 below:

Table 1. Test Results	
Property	Test Result
Tensile Strength, psi • As Received	29.2
Compressive Strength @ 10% Deformation, psi • As Received	43.5

If there are any questions regarding the results contained in this report, or any of the other services offered by Intertek, please do not hesitate to contact the undersigned. Please note this Letter Report does not represent authorization for the use of any Intertek certification marks.

Completed by:	Chris Chang, P.Eng.	Reviewed by:	Baldeep Sandhu
	Engineer Building Products	Title:	Manager Building Products
Signature:		Signature	

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only the sample tested. This report by itself does not imply that the material, product or service is or has ever been under an Intertek certification program.

